

MIWP LIMITS

storm water

	local	CA Haz Waste (STLCs for HM)
pH	5 - 12.5	2 - 12.5
O & G	500	na
dissolved sulfides	1	
flash point	> 140° F	
temperature	150° F	
cyanide, t	1.9	
cyanide, a	na	
cadmium	3.8	(1)
chromium	59	(5)
copper	(11)	25
lead	73	(5)
nickel	(13)	20
silver	na	5
zinc	(24)	250
TTO	na	na
total metals	na	na
benzene	na	0.5
fluoride	na	

0 ppb

30 ppb

20 ppb

7 ppb

☛ Semiconductor mfr PSES (469.16) & F

BETWEEN THE LOCAL LIMIT AND
THE CA HAZ WASTE LIMIT, THE
LOWER OF THE TWO, CIRCLED, WILL
BE ENFORCED